

## Certificate of Product Approval

Certificate Number: 566f

Issue: 04

### Rapidrop Global Limited

Rutland Business Park  
Newark Road  
Peterborough  
PE1 5WA  
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Model RD107 Sprinkler

(refer to attached appendix for details)

#### Standards

##### EN 12259-1:1999 including amendment +A3:2006

Fixed firefighting systems. Components for sprinkler and water spray systems. Sprinklers

This certificate and appendix is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd.

Caner Ozgul

Verifier

14 December 2020

Date of Issue

24 October 2011

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 566f Rapidrop Global Limited

Issue: 04

### Model RD107 Sprinkler

Product Name	Nominal orifice size (mm)	Type	Temperature rating (°C)	LPCB Ref. No.
Rapidrop RD107	15	SCCP	72 with 60 cover plate	566f/01

#### Notes:

- (1) This sprinkler must be handled with care, and the protective cap which protects the thermal element should only be removed after ceiling installation is completed. To be installed in accordance with the Rapidrop Installation Instructions specific to the sprinkler.
- (2) Approved with chrome and coloured cover plates.
- (3) Not to be installed in ceilings with a positive pressure in the void above.
- (4) These sprinklers are approved for use with the Lumi Plugin LP110 fitted co-axially with the sprinkler. Their installation must comply with Rapidrop product Data Sheet D.S. 14.01, Issue D 18.06.2020 and the sprinkler installation instructions for the particular sprinkler being fitted.

This certificate and appendix is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd.

Caner Ozgul

Verifier

14 December 2020

Date of Issue

24 October 2011

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


